

ANALYTICAL REPORT

Page 1 of 1

Patrick Farrelly
Aqua-Nu Filtration Systems
Brid a Crinn
Dundalk
Co Louth
Ireland

Certificate Number: 63448-1 Final

Order Number:

Task Number: 1753

Date Received: 15/05/2011

Date Reported: 16/05/2011

Lab Ref.	Sample Details	Method	Test	Result	Units	Flag
1347886	Description: AQUA-NU, FILTER No D 36, 11L Sample Type: FILTER Received Date: 15-MAY-11 Sampling Date: 11-MAY-11	420	Cryptosporidium	0	oocysts/l	
			Findings	See #1 below		*
		420	Giardia	0	cysts/l	
		420	Volume Examined	11	l	F

#1 - Filter challenged with 11 L DI Water, spiked with approximately 200 Cryptosporidium Oocysts and 200 Giardia Cysts. Tested by filtering via gravity.



Richard Brown
Laboratory Manager

Disclaimers:

Unless otherwise stated, all results are expressed on an as received basis.

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.

ext - Analysis subcontracted to an external laboratory

doc - individually documented method, details available on request

F - result exceeds the maximum PCV as defined in the Water Supply (Water Quality) Regulations 2000

* - denotes non UKAS accredited method

A result of 0 cfu denotes none found in volume analysed

The start date of analytical testing and Uncertainty of Measurement are available on request

All analytical quality control associated with these results was satisfactory, details are available on request



1579