

Certificate of Analysis

Customer: Aqua Nu

Report Reference: 11-01595-

Customer Address: Bridacrinn
Dundalk
County Louth

Date Received: 29/04/2011

Customer Contact: Patrick Farrelly

Page 11 of 11

Sample Description: B9
Sample Type: Treated Water
Date Sampled: Not Advised
Lab Reference Number: 103283

Site/Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value	Accreditation Status
D/1206	29/04/2011	Total Volume Analysed	10	l		NON
D/1206	29/04/2011	Cryptosporidium	<0.01	Oocysts/10L		NON
D/1213	29/04/2011	Total Volume Analysed	10	l		NON
D/1213	29/04/2011	Giardia	<0.01	Cysts/10L		NON

Note:

NAC & ATC - No abnormal change and acceptable to customers.

PV Value is the parametric value, taken from European Communities, (Drinking Water) (No. 2) Regulations, 2007. S.I. No. 278 of 2007, and relates only to drinking water samples.

Site D = Analysed at City Analysts Dublin. Site L = Analysed at City Analysts Limerick

Template 1146
Revision 011